



Notes

- 1) Drawings are not to scale. Refer to submittal drawings for actual dimensions and weights. All dimensions are in feet and inches, Weights are in pounds.
- 2) Unless otherwise indicated, connections 3" and smaller are MPT. Connections 4" and larger are grooved to suit a mechanical coupling and beveled for welding.
- 3) Dimensions showing location of coil and basin connections are approximate and should not be used for prefabrication of connecting piping.
- 4) For weight loadings and support requirements, refer to the suggested steel support drawing.
- 5) Heaviest section is the combined weight of fan and coil sections, refer to the rigging and assembly manual for suggested lifting method.
- 6) The area above the discharge must be unobstructed.
- 7) Do not support piping from unit connections. All necessary piping supports to be supplied by others.
- 8) M = Motor location.

Right Hand Unit

Model Number	Approx. Shipping Weight	Approx. Operating Weight	Heaviest Section Weight	F	H
PFI-0406N-3DXDZ-X1	3210	4690	2580	4'-0 5/8"	12'-5 1/2"
PFI-0406N-3DXEZ-X1	3670	5230	3030	5'-3 5/8"	13'-8 1/2"
PFI-0406N-4DXEZ-X1	3810	5400	3170	5'-11 1/8"	14'-4"
PFI-0406N-4DXDZ-X1	3670	5310	3040	4'-8 1/8"	13'-1"
PFI-0406N-5DXEZ-X1	4110	5810	3480	6'-5 5/8"	14'-10 1/2"
PFI-0406N-5DXDZ-X1	4470	6350	3840	5'-3 5/8"	13'-8 1/2"
PFI-0406N-6DXDZ-X1	4540	6420	3910	5'-11 1/8"	14'-4"

ORDER NO:

DATE:



BALTIMORE AIRCOIL COMPANY

PFI Closed Circuit Cooling Tower Tabulated Unit Print

DRAWING NUMBER:
UP-PFI-0406