



MODEL NO.	APPROX. SHIPPING WEIGHT	APPROX. OPERATING WEIGHT
VCA-300A	12270	18340
VCA-331A	12330	18400
VCA-340A	13950	20110
VCA-375A	14010	20170
VCA-402A	14030	20190
VCA-407A	15710	21960
VCA-401A	16660	22970
VCA-429A	16680	22990
VCA-473A	16820	23130
VCA-393A	18440	24850
VCA-433A	18500	24910
VCA-464A	18520	24930
VCA-512A	18660	25070

Notes

- 1) All dimensions are in feet and inches. Weights are in pounds and do not include options and accessories.
- 2) Supporting steelwork and anchor bolts to be designed and furnished by others.
- 3) All supporting steel must be flush and level at top.
- 4) Each beam should be designed, as a minimum, for 65% of the total unit operating weight applied as a uniformly distributed load.
- 5) Beams should be selected in accordance with accepted structural practice, maximum deflection of beam under the unit to be 1/360 of span, not to exceed 1/2 inch.
- 6) If vibration isolation rails are used between unit and supporting steel, be certain to allow for the length of the vibration rails when determining length of supporting steel. Vibration rail length and mounting hole locations may differ from those of the unit. Refer to vibration isolator manufacturer drawings for this data.
- 7) Do not use this drawing to size point vibration isolators.

ORDER NO: _____

DATE: _____



Baltimore Aircoil

VCA Unit Support
10'x12'

DRAWING NUMBER: _____