



NOTES:

1. ALL DIMENSIONS ARE IN FEET AND INCHES. WEIGHTS ARE IN POUNDS.
2. UNLESS OTHERWISE INDICATED ALL CONNECTIONS 3 INCHES AND SMALLER ARE MPT AND CONNECTIONS 4 INCHES AND LARGER ARE BEVELLED FOR WELDING AND GROOVED FOR VICTAULIC CONNECTION.
3. FOR SUPPORT REQUIREMENTS, REFER TO THE SUGGESTED STEEL SUPPORT DRAWING.
4. PRE-FABRICATION OF FINAL CONNECTING PIPEWORK IS NOT RECOMMENDED.
5. DO NOT SUPPORT PIPING FROM COOLING TOWER. ALL NECESSARY PIPE SUPPORTS ARE TO BE SUPPLIED BY OTHERS.

* UNIT SHIPS IN ONE PIECE.

MODEL NO.	APPROX. SHPG. WEIGHT	APPROX. OPER. WEIGHT	HEAV. SECT. (PAN)	A	H
VTO-12-E	790	960	790 *	6'-7 7/8"	7'-6 1/8"
VTO-14-F	800	970	800 *	6'-7 7/8"	7'-6 1/8"
VTO-19-G	820	990	820 *	6'-7 7/8"	7'-6 1/8"
VTO-24-G	950	1050	630	8'-1 7/8"	9'-0 1/8"
VTO-28-H	970	1170	650	8'-1 7/8"	9'-0 1/8"

B.A.C.
ORDER NO:

DATE: / /



BALTIMORE AIRCOIL
COMPANY

COOLING TOWER

DRAWING NUMBER:
BAC-9103 A

C