

<u></u>	⊨	
, ,		ΙΕM
		ELEVATION VIEW
		ELEV.
 	 -	

Model Number	Approx, Shipping Weight	Approx, Operating Weight
PFI-1212N-2DXDS-X1	13420	20180
PFI-1212N-2DXES-X1	14330	21130
PFI-1212N-3DXDS-X1	15600	23250
PFI-1212N-3DXES-X1	16780	24480
PFI-1212N-4DXDS-X1	17380	25590
PFI-1212N-4DXES-X1	18860	27460
PFI-1212N-5DXDS-X1	20330	29770
PFI-1212N-5DXES-X1	21330	30820
PFI-1212N-6DXDS-X1	19320	28300

Notes

1) Drawings are not to scale. All dimensions are in feet and inches, weights are in pounds.

Refer to submittal drawings for actual dimensions and weights.

- 2) Operating weight and weight loading are for units with water level in basin at overflow.
- 3) Unit support beams and anchor bolts to be designed and furnished by others.
- 4) Support beams must be flush and level at top.
- 5) All supporting steelwork must be designed in accordance with accepted structural practice. Maximum deflection of steelwork under unit to be 1/360 of span, not to exceed 1/2".
- 6) Each beam should be designed, as a minimum, for 65% of the total unit operation weight applied as a uniformly distributed load.

ORDER NO:

DATE:



PFI Closed Circuit Cooling Tower
Tabulated Steel Support - Plan A

DRAWING NUMBER:

SS-PFI-1212