

- 1) Drawings are not to scale. All dimensions are in feet and inches, weights are in pounds. Refer to submittal drawings for actual dimensions and weights.
- 2) Operating weight and weight loading are for units with water level in basin at overflow.
- 3) Unit support beams and anchor bolts to be designed and furnished by others.
- 4) Support beams must be flush and level at top.
- 5) All supporting steelwork must be designed in accordance with accepted structural practice.

Maximum deflection of steelwork under unit to be 1/360 of span, not to exceed 1/2".

6) Each beam should be designed, as a minimum, for 65% of the total unit operation weight applied as a uniformly distributed load.

ORDER NO:	BALTIMORE AIRCOIL COMPANY
DATE:	AMISSIE SSMPART

51400

55150

59780

61880

56840

58980

PFI Closed Circuit Cooling Tower Tabulated Steel Support - Plan A

DRAWING NUMBER:

SS-PFI-1224

PFI-1224N-4DXDS-X2

PFI-1224N-4DXES-X2

PFI-1224N-5DXDS-X2

PFI-1224N-5DXES-X2

PFI-1224N-6DXDS-X2

PFI-1224N-6DXES-X2

34980

37950

40890

42900

38870

40940