


1)	Dra
1)	Dia

- awings are not to scale. Refer to submittal drawings for actual dimensions and weights. All dimensions are in feet and inches, Weights are in
- 2) Unless otherwise indicated, connections 3" and smaller are MPT. Connections 4" and larger are grooved to suit a mechanical coupling and beveled for welding.
- 3) Dimensions showing location of coil and basin connections are approximate and should not be used for prefabrication of connecting piping.
- 4) For weight loadings and support requirements, refer to the suggested steel support drawing.
- 5) Heaviest section is the combined weight of fan and coil sections, refer to the rigging and assembly manual for suggested lifting method.
- 6) The area above the discharge must be unobstructed.
- 7) Do not support piping from unit connections. All necessary piping supports to be supplied by others. 8) M = Motor location.

Right Hand Unit



Model Number	Weight	Weight	Weight	F	Н
PFI-1212N-2DXDS-X1	13420	20180	10930	4'-0 5/8"	16'-0 3/4"
PFI-1212N-2DXES-X1	14330	21130	11830	4'-8 1/8"	16'-8 1/4"
PFI-1212N-3DXDS-X1	15600	23250	13100	4'-0 5/8"	16'-0 3/4"
PFI-1212N-3DXES-X1	16780	24480	14280	5'-3 5/8"	17'-3 3/4"
PFI-1212N-4DXDS-X1	17380	25590	14880	4'-8 1/8"	16'-8 1/4"
PFI-1212N-4DXES-X1	18860	27460	16360	5'-11 1/8"	17'-11 1/4"
PFI-1212N-5DXDS-X1	20330	29770	17830	5'-3 5/8"	17'-3 3/4"
PFI-1212N-5DXES-X1	21330	30820	18830	6'-5 5/8"	18'-5 3/4"
PFI-1212N-6DXDS-X1	19320	28300	16820	5'-11 1/8"	17'-11 1/4"
PFI-1212N-6DXES-X1	20360	29370	17850	7'-1 1/8"	19'-1 1/4"

Approx,

Shipping Operating

Heaviest

Section

ORDER NO:

DATE:



PFI Closed Circuit Cooling Tower Tabulated Unit Print

DRAWING NUMBER:

UP-PFI-1212