
MODEL	APPROX.	APPROX.	LATENT	TANK	COIL	IN/OUT	DIMENSIONS					
NO.	SHIPPING WEIGHT	OPERATING WEIGHT*	CAPACITY (T-H)	VOLUME (GALLONS)	VOLUME (GALLONS)	SIZE	W	L	Α	В	С	D
TSU-L184M	8300	31700	184	2330	205	2"	7'-10 3/8"	10'-7 5/8"	8 5/8"	15 1/4"	23 5/8"	16 5/8"
TSU-L370M	14100	59700	370	4560	385	3"	7'-10 3/8"	19'-10 1/4"	9 3/4"	15 1/4"	23 5/8"	16 5/8"
TSU-L462M	17000	75000	462	5820	477	3"	9'-9 1/4"	19'-10 1/4"	9 3/4"	23"	21 3/4"	27 3/4"
TSU-L592M	20300	91650	592	7140	602	3"	11'-9 3/4"	19'-10 1/4"	9 3/4"	27 1/8"	23 5/8"	40 1/4"


* OPERATING WEIGHT IS FOR UNIT WITH WATER LEVEL AT OVERFLOW LEVEL




NOTES:

- 1. ALL DIMENSIONS ARE IN FEET AND INCHES. WEIGHTS ARE IN POUNDS.
- DIMENSIONS LOCATING COIL CONNECTIONS ARE APPROXIMATE AND SUBJECT TO SOME VARIATION. THEY SHOULD NOT BE USED TO PREFABRICATE PIPE.
- 3. UNIT SHOULD BE CONTINUOUSLY SUPPORTED ON A FLAT LEVEL SURFACE.

ALL CONNECTIONS ARE GROOVED TO SUIT A MECHANICAL COUPLING. TO AVOID DAMAGE TO INSULATION AND TANK LINING NO WELDING IS PERMITTED AT THE TANK CONNECTIONS.






END ELEVATION

SIDE ELEVATION

MODEL TSU-L370M SHOWN OTHER MODELS SIMILAR

E	3.A.C. DRDER	NO:			
	ATE:				



ICE CHILLER[®] THERMAL STORAGE UNIT

DRAWING NUMBER:

BAC-10268 A