



Notes

- 1) Supporting steelwork and anchor bolts to be designed and furnished by others.
- 2) All supporting steel must be level at top.
- 3) Beams should be selected in accordance with accepted structural practice, maximum deflection of beam under unit to be 1/360 of span, not to exceed 1/2 inch.
- 4) Supporting steel will be greater than or equal to the length of the basin.
- 5) Each beam should be designed, as a minimum, for 65% of the total unit operating weight applied as a uniformly distributed load.
- 6) Do not use this drawing to size point vibration isolators. See your BAC Representative for details.
- 7) All Dimensions are in feet and inches. All weights are in pounds.
- 8) Weights include all of the options and accessories.

PLAN "A" STEEL

Model Number	Shipping Weight	Operating Weight
VF1-1012N-XXXXX-XX		

ORDER NO: _____

DATE: _____



BALTIMORE AIRCOIL COMPANY

Single Cell Unit Support

DRAWING NUMBER:
10X12 Unit Support